

Guideline

9/8

CLAP

FORM N°107

Version : 2

Directive 97/23/EC

Keywords :

Piping

CE marking

Directive references:

Article 3 § 1.3 - 97/23 EC

Article 15 § 2 - 97/23 EC

Adopted by WPG: 08/11/1999

Adopted by CLAP: 08/11/1999

Subject: ESR on manufacturing – Piping part of an industrial installation

Question: Conformity with the PED is required for some piping per Article 3.1.3, which are part of an industrial installation. May all such piping for a given installation be covered by a single CE marking?

Answer: Yes, providing the CE marking is prominently displayed and the accompanying documentation supplied by the manufacturer to the user clearly defines the boundary of the installation.

Modifications compared to the previous adopted version: Editorial correction on 2004-09-16.