

Directive 97/23/CE**Keywords:** Temperature

Proof test

Final inspection

Quantitative requirement

Directive reference: Article 1 § 2.4 - 97/23 EC

Annex I § 7.4 - 97/23 EC

Adopted by CLAP: 10/07/2003**Subject:** ESR on manufacturing – Temperature of the test pressure**Question:** What is the temperature to be taken into account for the load ratio in the determination of the test pressure?**Answer:**

It is the maximum allowable temperature as defined in Article 1 § 2.4 and not the highest value of the calculation temperature of the different components.

Example: In the case of a boiler, the maximum allowable temperature is not the calculation temperature of the furnace plate.

Modifications compared to the previous adopted version: Deletion of the references to WPG and editorial correction on 2004-09-16.