

Directive 97/23/EC**Keywords :**

Periodic inspection

Installations' safety

DN

Directive references:

Annex I § 3.3.b) - 97/23 EC

Adopted by CLAP:**25/03/2014****Subject:**

Scope - Mandatory character of Information covered by Annex I § 3.3b) of PED

Question:

Shall the marking of a pressure equipment mandatory include Information covered by Annex I § 3.3b) of PED? (as an example : Does a vessel where group of fluids or volume are not indicated comply with Essential Requirements?)

Answer:

If Information covered by the Essential Requirements 3.3.b are necessary to the safety installation, operation or use, and if required; maintenance and periodic inspection; they shall be affixed on the equipment. Considering the issue of the safety's installation, especially for vessels, Information on V, group of fluids, test pressure shall be mentioned.